



May, 29, 2024

**ADDENDUM NO. 1
MECHANICAL IMPROVEMENTS
AT GLENVIEW TRANSFER STATION
SOLID WASTE AGENCY OF NORTHERN COOK COUNTY (SWANCC)
PROJECT NO. 23122.1**

Solid Waste Agency of Northern Cook County (SWANCC)
77 West Hintz Road
Wheeling, Illinois 60090

The Contractor/Bidder shall acknowledge in writing on his bid proposal form the receipt of this Addendum.

This Addendum shall be part of the Specifications and Drawings for this project and shall be part of the actual contract document to complete the work. When the Architect issues an Addendum, it is the Bidder's responsibility to copy and insert it into the bid documents they have obtained from the Architect or Owner.

There are Two (2) items in this Addendum.

ITEM NO. 1: DRAWINGS, HV0.1 PARTIAL SECOND FLOOR PLANS – HVAC DEMOLITION

1. HVAC Demolition Drawing Notes – Revise note 6 to read as follows: "REMOVE EXISTING AIR HANDLING UNIT AND ALL ASSOCIATED DUCTWORK, DAMPERS, PIPING, VALVING, CONTROLS, HANGERS, SUPPORTS, INSULATION, CONDENSATE PUMP, SMOKE DETECTOR, DISCONNECTS ETC."

ITEM NO. 2: CLARIFICATIONS

1. The working hours within the Baling Area of the Transfer floor shall be limited to Tuesday through Friday between 4:00 PM and 5:00 AM of the following day or between Saturday at 12:00 PM to Tuesday at 5:00 AM, inclusive of Sunday and Monday with no hourly restrictions. Work hours and access must be coordinated with the owner. All other work areas will be accessible at any time.
2. The elevator may be used by the contractor. If used, the cab must be protected, and the material shall not exceed the posted maximum weight limit. Photos must be submitted to ARCON and the owner prior to use.
3. Staging of Crane lifts shall not impede travel around the perimeter of the building. Parking spots and the grass area around the building can be utilized. Lifts can occur anything allowed by local codes. It is the contractor's responsibility to ensure that there are no building occupants below the radius of the crane's boom during crane activities. All pick times shall be coordinated with the owner.
4. There will be a roofing contractor on site during the duration of the project (Riddiford Roofing). It is imperative that all Mechanical Improvement work is coordinated with the with Riddiford Roofing.

ADDENDUM NO. 1
MECHANICAL IMPROVEMENTS
AT GLENVIEW TRANSFER STATION
SOLID WASTE AGENCY OF NORTHERN COOK COUNTY (SWANCC)
PROJECT NO. 23122.1
PAGE 2

5. Attached is the sign-in sheet from the Mandatory Pre-Bid Meeting held on 5/21/2024 at 9:00 a.m.

END OF ADDENDUM NO. 1

BEM

"J:\SWANCC\23122.1 Mechanical Improvements @ Glenview Transfer Station\1 Spec\Addendum No. 1\23122.1AD1.pdf"



construction managers
www.arconassoc.com

Mechanical Improvements at Glenview Transfer Station

Solid Waste Agency of Northern Cook County (SWANCC)

#23122.1 Date: 5/21/2024 Time: 9:00 AM

Mandatory Pre-Bid Meeting



Name	Company	Phone	Email
Brian Medlicott	Morris Mechanical	630-469-7800	bmedlcoffa@morrismechanical.com
Anthony Acitelli	C. Acitelli	630-832-4645	anthony@acitelli.com
Jim Christman	Istecorator Dene	708-958-8386	jmcristmator@dene.com
CASEY REYES	MG MECHANICAL	847-971-4146	CREYES@MGMMECHANICAL.NET
Mike Kapst	Helm Mech	708 989 6073	mkapst@helmingroup.com
STEVE SCHAFER	CSA DESIGN GROUP	847 981 - 1880	SCHAFER@CSADESIGNGROUP.COM
AMANDRA SHEKHAR KUMAR	CS2 DESIGN GROUP	847-981-1880	EKUNMAR@CS2DESIGNGROUP.COM
Juan Palomo	ARC ON	630-343-9797	JJPALOMO@ARC.ONASSOC.COM
Christina Seibert	SWANCC	847-243-4710	christna@swancc.org
Gina Mando	Allstate Concrete cutting	224-435-1604	gmando@allstatec.com
DAVE TABEL	AMBER MECH.	708/351-0446	ESTIMATING@AMBERMECH.COM
DAMIAS MADEIRO	Connally Elect.	224-291-1851	DMAIDRO@connallyelectr.com